



Klimat:

| ID: | Tip: | Rekup. [%] | Sveži zr. [%] | Q° g [kW] | Q° h [kW] | S/E: | V° [m3/h] | dp ex [Pa] | P [kW] | U [V] | m [kg] |
|------|--------------------|------------|---------------|-----------|-----------|------|-----------|------------|--------|-------|--------|
| KN.1 | Klimat higienik II | 89 | 100 | 3 | 10 | S | 1350 | 225 | 0,75 | 230 | 1.055 |
| | | | | | | E | 1400 | 235 | 0,45 | 230 | |

REGULACIJSKI VENTILI:

| Oznaka: | Tip ventila: | Tip motor: | DN [mm] | Kvs [m3/h] | M [Nm] F [N] | U [V] |
|---------|--------------|-------------|---------|------------|-----------------|-------|
| KN1.MV1 | VRG3 20/6,3 | AMV 435/24V | DN20 | 6,3 | 400 | 24 |

| | | | | | | | | |
|---|--|--------------------|------------------------|----------------|------------------|---|-------------------|---|
| <i>Risba:</i> | SHEMA KLIMATA KN.1 | | | | | | | |
| <i>Vsebina risbe:</i> | VENTILACIJA | | | | | | | |
| <i>Investitor:</i> | SPLOŠNA BOLNIŠNICA "DR. FRANCA DERGANCA" NOVA GORICA Ulica padlih borcev 13A, 5290 Šempeter pri Gorici | | | | <i>Podjetje:</i> | PINSS d.o.o. Kromberk, Industrijska c. 5, NOVA GORICA T: +386 5 333 44 50, F: +386 5 333 44 52 M: pinss@siol.net | |  |
| <i>Objekt:</i> | CT | | | | <i>Pl:</i> | Marko PEGAN, dis S-1243 | | |
| | | | | | <i>Izdelal:</i> | Marko PEGAN, dis S-1243 | | |
| | | | | | | | | |
| <i>Vrsta načrta:</i> | STROJNE INSTALACIJE | | | | | | | |
|  | <i>Št. projekta:</i> | <i>Št. načrta:</i> | <i>Vrsta projekta:</i> | <i>Merilo:</i> | <i>Datum:</i> | <i>Mapa:</i> | <i>Št. risbe:</i> | |
| | | 19-12-04-1 | PZI | | 12.2019 | 4 | 303 | |